

# LICENCE



europaean  
building  
automation  
controls  
association

Number: **221060**

**REVAME**

received the licence to use the eu.bac mark for the product

**COLIBRI**

for the application(s)

Variable air volume system (without h/c coil)

based on the certification rules of eu.bac  
and the Certificate 216400

This licence will expire on **17 December 2027**



221060

**17 December 2021**  
Brussels


Managing Director Dr. Peter Hug  
eu.bac



# Test Report Summary

Product Information	
Licence Number:	221060
Licensee:	REVAME
Product Identification	COLIBRI
Test Specifications	
Tested Application:	Variable air volume system (without h/c coil)
Temperature Sensor	
- Type:	Revame_NTC_10K
- Time Constant:	6 Mins
Actuator Identification	Belimo CM24-SR
- Type:	Motorized: 0-10V
Valve Identification	
- Characteristic	None
AV Acronym	24Vdc/MA/0-10V/**/**
Fan Speed (For Fan Coil Applications)	
- Characteristic	None
Test Result	
Temperature Control Accuracy $C_A$ according EN 15500	Heating - 0.1 K Cooling - 0.1 K

17 December 2021  
Brussels

  
 Managing Director Dr. Peter Hug  
 eu.bac